



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague
Akreditované zkušební laboratoře, Autorizovaná osoba,
Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 00 Praha 10



Notified Body 1390

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1390 – CPR – 0342/12/P

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Factory made mineral wool products used for building equipment and industrial installations, sold under the trade mark

ALU LAMELLA MAT; Larock 40 ALS

KLIMAFIX; Ventizol

(trade marks and type codes according to list given in the annex to the certificate)

placed on the market by : **ROCKWOOL Polska, Sp.z o.o.**
ul. Kwiatowa 14
66-131 Cigacice, Poland

and produced in the manufacturing plant : **ROCKWOOL Polska, Sp.z o.o.**
ul. Kwiatowa 14
66-131 Cigacice, Poland (production line CIG 4)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14 303:2009+A1:2013

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 08. 08. 2012 as a certificate in accordance with CPD and will remain valid as long as neither the harmonised standard, the construction product, the AVPC methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body 1390
Prague, 28.11. 2017




Ing. Petr Kučera, CSc.
Deputy of Notified Body 1390



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague

Akreditované zkušební laboratoře, Autorizovaná osoba,

Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body

Pražská 16, 102 21 Praha 10



Annex to the CERTIFICATE OF CONSTANCY OF PERFORMANCE
1390-CPR-0342/12/P

The certificate covers the following products of Rockwool Polska Sp. z o.o.,
ul. Kwiatowa 14, 66-131 Cigacice, Poland

tab 1

| Trade mark | Thermal conductivity W/m·K | Reaction to fire | Type code in accordance with EN 14 303 |
|----------------------------------|----------------------------|------------------|--|
| ALU LAMELLA MAT Larock 40 ALS | see tab. 2 | A1 | MW EN 14 303-T4-ST(+)250-WS1-MV2 |
| KLIMAFIX Ventizol | | A2-s1;d0 | MW EN 14 303-T4-ST(+)50-WS1-MV2 |

tab 2

| Trade mark | λ_D Thermal dependence of thermal conductivity W/m·K | | | |
|----------------------------------|--|-------|-------|-------|
| | 10 | 50 | 150 | 250 |
| ALU LAMELLA MAT Larock 40 ALS | 0,039 | 0,050 | 0,083 | 0,134 |

| Trade mark | λ_D Thermal dependence of thermal conductivity W/m·K | |
|----------------------|--|-------|
| | 10 | 50 |
| KLIMAFIX Ventizol | 0,039 | 0,050 |



Notified Body 1390
Prague, 28. 11. 2017


Ing. Petr Kučera, CSc.
Deputy of Notified Body 1390